

C:\Users\UKJXP782\WSP 0365\70109716 - Caldicot Levels Solar Farm DCO - Documents (1)\03 - WIP\Drawings\ACAD\70109716-WSPE-Y-FG-00041_P01.dwg Originator: UKJXP782



2.4 MTR HIGH
COMPOUND
PERIMETER
PALISADE
FENCE

COMPOUND
ACCESS
ROADWAY

2.4 MTR HIGH
COMPOUND
PERIMETER
PALISADE
FENCE


54.2 MTR

EQUIPMENT LIST

ITEM No	DESCRIPTION
1	120MVA TRANSFORMER
2	SURGE ARRESTOR
3	DISCONNECTOR
4	HAM UNIT
5	SIEMENS TRIPLE POLE CIRCUIT BREAKER
6	WILSON AUXILLERY TRANSFORMER
7	P&C AND METERING & SWITCHROOM
9	CT
10	VT
11	CABLE SEALING END

Key

-  PEIR Assessment Boundary
-  Grid connection corridor



Reproduced from FEL-MC-9059-3401-P4

P01	JP	GG	SB	03/12/2025
FINAL				
REVISION	DRAWN	CHECKED	APPROVED	DATE
DESCRIPTION				



CLIENT NAME:
FUTURE ENERGY LLANWERN LTD

PROJECT TITLE:
**FUTURE ENERGY LLANWERN
SOLAR FARM PEIR**

DRAWING TITLE:
**FIGURE 2-16a
NORTH COMPOUND 3 - 33 kV
LAYOUT**

STATUS:
FINAL

DRAWN: JP	CHECKED: GG	APPROVED: JH	AUTHORISED: SB
--------------	----------------	-----------------	-------------------

SCALE @ A3 SIZE: 1: 250	DATE: 03/12/2025	REVISION: P01
----------------------------	---------------------	------------------

DRAWING NUMBER:
70109716-WSPE-Y-FG-00041_P01